DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmansa@gmail.com

TC-11288

TEST REPORT

Name & Address of Customer : **Gurukul Convent High School** **Gurukul Convent High School, Kahangarh, Bareta**		Customer Reference No.	**No : 825 Dated : 29/07/2026**
		Sample Submitted by	**Mr.Bhupinder Singh**
		Date of Sample Receipt	**29/07/2026**
		Analysis Starting Date	**30/07/2026**
		Analysis completion Date	**01/08/2026**
Discipline : **Chemical Testing**		Group: **Water**	
ULR No.:	**TC113862600000330F**	Sample Type :	**Water**
Test Report No.:	**DWTL/MNS/2627/00255**	Date of Issue :	**01/08/2026**
Registration no.:	**DWTL/MNS/REG2627/01149**	Condition of Sample :	**Unsealed**
Collection Point:	**Treatment Plant (RO/CWPP/ARP/HH Purifier)**	Quantity/Type of Bottle:	**1000 ml / Transparent Plastic Bottle**
Scheme/Source:	**Not Mentioned(Not Mentioned)**	Location/Depth :	**Gurukul Convent High School / NA**
Village :	**Kahngarh**	Habitation :	**Kahngarh**
Block:	**Budhlada**	District :	**Mansa**
Latitude :	**Not Mentioned**	Longitude:	**Not Mentioned**

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.94@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	NT	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	51	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL(0.5)	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity($CaCO_3$)	48	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness($CaCO_3$)	30	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	3.20	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	5.34	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	26.99	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For,District Water Testing Laboratory
Mansa

End of the Test Report

Scanned with OKEN Scanner

DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmansa@gmail.com

To,

Gurukul Convent High School
Gurukul Convent High School, Kahangarh, Bareta

No.: DWTL/MNS/2627/00255 Dated : 01/08/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 825 Dated: 29/07/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 29/07/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa

D/A : Test Report

Kamal Sharma

Authorized Signatory
For, District Water Testing Laboratory
Mansa

Scanned with OKEN Scanner